


Field drill 13mm holes into the wall mount and bolt sliders with the 12mm hardware provided

Adjust the diffuser 5 degrees towards the exterior of the building. Confirm diffuser adjustment after power has been supplied to the Air Barrier. See owners manual.



CE Certified

ENERSHIELD EUROPE  
 Calderhead Road  
 Shotts, Lanarkshire, Scotland  
 Tel. +44(0)1501 826501 FAX +44(0)1501 826501  
 E-mail: enquiries@enershield.eu  
 www.enershield.eu

**ENERSHIELD AIR BARRIER**

VOLTAGE  
 400/690V 3phase 50 Hz

Motor (s) IE2 @ 1465RPM  
 2 @ 15kW total  
 28.7/16.6 Amps FLA per motor  
 57.4/33.2 Amps FLA total

Blowers	Xtremeshield	XS-300
10	Air Velocity (fpm) (m/s)	7500/38.1
	Air Volume (cfm) (l/s)	59,563/28,111
	Total power (kW)	30
	Weight lbs/Kg	2200 lbs/998 Kg

Project:

Engineer:

Tag: